

Memo No:- 618

Date:- 26/04/2023

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : HSR/00289/4/2023 / Private	Sample Details	Date & Time
Sender : SHAHEED CAPTAIN ANIL DHAYAL PM SHRI GOVT. M.S.S.20267	Collected By	
Location : , VPO CHAMRKHHERA	Collection Date	25/04/2023 at 10:02
Sample Description : Drinking Water	Received at lab	25/04/2023 at 12:44
Latitude / Longitude : 75.807280 / 29.510965	Analysis Start Date	25/04/2023
	Analysis End Date	26/04/2023
	Sample Quantity	2 Ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Limit (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	356	500 mg/lt.	2000 mg/lt.	APHA2540 C; 2017
2	Total Hardness as CaCO ₃	184.8	200 mg/lt.	600 mg/lt.	APHA2340 C; 2017
3	Calcium as Ca	43.44	75 mg/lt.	200 mg/lt.	APHA3500-Ca B; 2017
4	Magnesium as Mg	18.56	30 mg/lt.	100 mg/lt.	APHA3500 Mg B; 2017
5	Iron as Fe	0.01	1.0 mg/lt.	1.0 mg/lt.	APHA3500-Fe B; 2017
6	Chloride as Cl	70.9	250 mg/lt.	1000 mg/lt.	APHA4500 Cl-B; 2017
7	Sulphate as So ₄	2.92	200 mg/lt.	400 mg/lt.	APHA4500-So ₄ -E
8	Fluoride as F	0.38	1.0 mg/lt.	1.5 mg/lt.	APHA 4500-F--C
9	Nitrate as No ₃	2.92	45 mg/lt.	45 mg/lt.	APHA 4500-NO ₃ - D
10	pH @ 25°C	7.22	6.5 - 8.5	6.5 - 8.5	APHA4500-H+ B; 2017
11	Total Alkalinity	100.4	200 mg/lt.	600 mg/lt.	APHA 2320 B; 2017

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED HISAR Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 15 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found "**POTABLE**"



Sample analyzed by :

jaipal

Rajeev
RAJEEV KUMAR ,CHEMIST
DISTRICT WATER TESTING LABORATORY,HISAR
email:-chemist.hisar@phedharyana.gov.in

-----END OF TEST REPORT-----



O/o Civil Surgeon , Hisar

Mail-Id:- dhs.cshsr@hry.nic.in

Letter No. HSR/DHO/HI/2023/ 63

Dated: 05-05-2023

OFFICE OF CIVIL SURGEON HISAR

Hygienic and Sanitation certificate


Certified that the condition of the building of

SHAHEED CAPTAIN ANIL DHAYAL PM SHRI GOVT. M.S.S. 20267

CHAMR. KHERA - HISAR With regards to the Sanitation and Hygienic

condition is satisfactory for the one year w.e.f date of issuing.


Dy Civil Surgeon(Health)

For Civil Surgeon, Hisar

05-05-23